No. 2013 - 0436



Safety Certificate

· Manufacturer SEMI LIGHTING CO.,LTD

Address

#328-32, Docheogwit-ro, Docheok-myeon, Gwangju-si,

Gyeonggi-do, Korea

The following product fabricated by the above manufacturer has been certified for the use of the Safety Certification Mark as the product was assessed and tested in accordance with the article 34 of the Occupational Safety & Health Act and the article 58 (4) 4 of the Enforcement Rule thereof.

· Product

LED Explosion proof Lighting fixture

Type(Model)

Exd IIB T6-L60-120

· Rating

Max. AC 240V, Max 60W

· Type of Protection

Ex d IIB+H2 T6 IP66

· Certification No.

13-GA2BO-0436

· Safety Certification Standards

Notification of Protective device Mandatory Safety Certification (Notice of Ministry of Employment and of Labor No. 2010-36)

1. Tamb = -20 °C \sim +40 °C

· Certification condition

2. Each product shall be submitted to a static overpressure test at 0.84 MPa.

position:

· Date of issue

June 4th, 2013

Approved for issue on behalf of the president :

Ki-Youn Song

General Manager

Signature



Korea Gas Safety Corporation