No. 2012 - 0729



Safety Certificate

· Manufacturer SEMI LIGHTING Co.,LTD.

 Address 328-32, Docheogwit-ro, Gwangju-si, Gyeonggi-do, Korea

The following product fabricated by the above manufacturer has been certified for the use of the Safety Certification Mark as the product was assessed and tested in accordance with the article 34 of the Occupational Safety & Health Act and the article 58 (4) 4 of the Enforcement Rule thereof.

· Product

LED lighting fixture

Type(Model)

nA-L120

· Rating

AC 240V Max, 120W Max

· Type of Protection

Ex nA II T5 IP66

· Certification No.

12-GA2BO-0729

· Safety Certification Standards

Notification of Protective device Mandatory Safety Certification (Notice of Ministry of Employment and of Labor No. 2010–36)

· Certification condition

Tamb = $-20 \, ^{\circ}\text{C} \, \sim \, +40 \, ^{\circ}\text{C}$

· Date of issue

December 4th, 2012

Approved for issue on behalf of the president: Young-jin Park

position : General Manager

Signature

Young Jim Park



Korea Gas Safety Corporation